



PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Plain Safety PAT Inspection

Number S240918C

DETAILS OF CLIENT

Client:

HUSSYBAND

TEST EQUIPMENT DETAILS

Test Equipment used

Martindale EasyPAT 1600

Serial Number

120697774

Tested by:

David Mason T/A Plain Safety

Date:

24.9.18

Re-test Date

24.9.20

Appliance Code	Make and model	Visual	Voltage (V)	Insulation resistance	*Earth continuity	Plug, flex and body	OK to use ?
2128	HK Linear 5 L Sub A	Pass	240	Pass	Pass	As New	Y
2129	HK Linear 5 112 FA Top	Pass	240	Pass	Pass	As New	Y
2130	HK Linear 5 112 FA Top	Pass	240	Pass	Pass	As New	Y
2131	Mackie SRM Speaker	Pass	240	Pass	Pass	As New	Y
2132	Kemper Power Head	Pass	240	Pass	Pass	As New	Y
2133	Stairville MHX	Pass	240	Pass	Pass	As New	Y
2134	Stairville MHX	Pass	240	Pass	Pass	As New	Y
2135	Stairville DMX Master	Pass	240	Pass	Pass	As New	Y
2136	Blackstar HT 60	Pass	240	Pass	Pass	As New	Y
2137	LEDJ Q Batten Light	Pass	240	Pass	Pass	As New	Y
2138	LEDJ Q Batten Light	Pass	240	Pass	Pass	As New	Y
2139	Ledj Floor Lamp 1	Pass	240	Pass	Pass	As New	Y
2140	Ledj Floor Lamp 2	Pass	240	Pass	Pass	As New	Y
2141	Allen & Heath QU16 Mixer	Pass	240	Pass	Pass	As New	Y
2142	iPod Charge Plug	Pass	240	Pass	Pass	As New	Y
2143	Ext 1	Pass	240	Pass	Pass	As New	Y
2144	Ext 2	Pass	240	Pass	Pass	As New	Y
2145	Ext 3	Pass	240	Pass	Pass	As New	Y
2146	Ext 4	Pass	240	Pass	Pass	As New	Y
2147	Pedal Power	Pass	50V DC	Pass	Pass	As New	Y
2148	Pedal Power Supply	Pass	50V DC	Pass	Pass	As New	Y
2149	Ext 5	Pass	240	Pass	Pass	As New	Y
2150	Ext 6	Pass	240	Pass	Pass	As New	Y
2151	Ext 7	Pass	240	Pass	Pass	As New	Y
2152	Ext 8	Pass	240	Pass	Pass	As New	Y
2153	IEC 9	Pass	240	Pass	Pass	As New	Y
2154	IEC 10	Pass	240	Pass	Pass	As New	Y
2155	IEC 11	Pass	240	Pass	Pass	As New	Y
2156	IEC 12	Pass	240	Pass	Pass	As New	Y
2157	IEC 13	Pass	240	Pass	Pass	As New	Y
2158	IEC 14	Pass	240	Pass	Pass	As New	Y
2159	IEC 15	Pass	240	Pass	Pass	As New	Y
2160	IEC 16	Pass	240	Pass	Pass	As New	Y
2161	IEC 17	Pass	240	Pass	Pass	As New	Y
2162	IEC 18	Pass	240	Pass	Pass	As New	Y
2163	IEC 19	Pass	240	Pass	Pass	As New	Y
2164	IEC 20	Pass	240	Pass	Pass	As New	Y
2165	IEC 21	Pass	240	Pass	Pass	As New	Y
2166	Behringer Headphone Amp	Pass	240	Pass	Pass	As New	Y

* Pass indicates a recorded Earth Continuity of less than 1 ohm. ** Class 3 device powered by external 50v DC.

Notes: For the purpose of this PAT Report, it should be noted that visual PAT tests were conducted on all non mains powered speakers as is necessary for this type of peripheral equipment. Earth Pins checked for plug only tests.