

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 22/04/2014 To: 09/05/2014

Site: Mike Georgiades

Location: general

Asset ID: 103716	Description: 13a iec lead	User: admin	Test Instrument: Seaward Apollo 500 39E-0135
------------------	---------------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	09/05/2014			Pass
Flex	09/05/2014			Pass
Enclosure	09/05/2014			Pass
Environment	09/05/2014			Pass
Socket	09/05/2014			Pass
Switch	09/05/2014			Pass
Voltage	09/05/2014	230	V	Information
IEC Lead Continuity	09/05/2014	0.07	ohm	Pass
Insulation Voltage	09/05/2014	500	V	Information
Insulation	09/05/2014	> 19.99	MOhm	Pass
IEC Lead Polarity	09/05/2014			Pass

Overall: Pass

Asset ID: 103717	Description: amp	User: admin	Test Instrument: Seaward Apollo 500 39E-0135
------------------	------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	09/05/2014			Pass
Flex	09/05/2014			Pass
Enclosure	09/05/2014			Pass
Environment	09/05/2014			Pass
Socket	09/05/2014			Pass
Switch	09/05/2014			Pass
Voltage	09/05/2014	230	V	Information
Insulation Voltage	09/05/2014	250	V	Information
Insulation	09/05/2014	> 19.99	MOhm	Pass

Overall: Pass

Total Tests: 2