

Test Certificate



Testing Date Range From: 29/01/2015 To: 29/01/2015

*Note - Items were not function tested

Client: Daniel Benisty	Site: 7 Ashley Court	Location: FLAT
-------------------------------	-----------------------------	-----------------------

AssetID: 126483	Description: AC ADAP	Make: SEINHEISER	Model:
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983		

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
Overall: Pass					

AssetID: 126484	Description: AC ADAP	Make: SHURE	Model: 612B
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983		

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
Overall: Pass					

AssetID: 126485	Description: IEC LEAD	Make:	Model:
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983		

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.04	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016
Overall: Pass					

AssetID: 126486	Description: EXT LEAD	Make: KF	Model:
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983		

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.1	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	250	V	Information	29/01/2016
Insulation	29/01/2015	1.83	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016
Overall: Pass					

AssetID: 126487	Description: EXT LEAD	Make: PMS	Model:
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983		

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.112	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	250	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016
Overall: Pass					

AssetID: 126488	Description: IEC LEAD	Make:	Model:
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983		

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.022	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016
Overall: Pass					

AssetID: 126489	Description: AC ADAP	Make: YAMAHA	Model: 150A
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983		

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
Overall: Pass					

AssetID: 126490	Description: AC ADAP	Make: TASCAM	Model: 6935
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983		

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016

Signed By: 

Test Certificate



Testing Date Range From: 29/01/2015 To: 29/01/2015

*Note - Items were not function tested

Insulation 29/01/2015 > 199 MOhm Pass 29/01/2016
Overall: Pass

AssetID: 126491 Description: POWERLEAD Make: Model:

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016

Overall: Pass

AssetID: 126492 Description: AC ADAP Make: APD Model: 6969

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016

Overall: Pass

AssetID: 126493 Description: IEC LEAD Make: Model:

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.062	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016

Overall: Pass

AssetID: 126494 Description: IEC LEAD Make: Model:

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.054	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016

Overall: Pass

AssetID: 126495 Description: IEC LEAD Make: Model:

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.054	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016

Overall: Pass

AssetID: 126496 Description: IEC LEAD Make: Model:

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.058	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016

Overall: Pass

AssetID: 126497 Description: IEC LEAD Make: Model:

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.038	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016

Overall: Pass

Signed By:

Test Certificate



Testing Date Range From: 29/01/2015 To: 29/01/2015
*Note - Items were not function tested

AssetID: 126498	Description: IEC LEAD	Make:	Model:		
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments				
Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.038	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016
Overall: Pass					

AssetID: 126499	Description: IEC LEAD	Make:	Model:		
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments				
Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.042	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016
Overall: Pass					

AssetID: 126500	Description: IEC LEAD	Make:	Model:		
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments				
Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.04	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016
Overall: Pass					

AssetID: 126501	Description: IEC LEAD	Make:	Model:		
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments				
Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.076	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016
Overall: Pass					

AssetID: 126502	Description: AC ADAP	Make: POWER	Model:		
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments				
Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
Overall: Pass					

AssetID: 126503	Description: SPEAKER	Make: YAMAHA	Model: 1358		
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments				
Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Earth Continuity	29/01/2015	0.068	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
Overall: Pass					

AssetID: 126504	Description: AC ADAP	Make: PANASONIC	Model:		
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments				
Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
Overall: Pass					

AssetID: 126505	Description: AC ADAP	Make: BS	Model: 50		
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments				
Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016

Signed By:

Test Certificate



Testing Date Range From: 29/01/2015 To: 29/01/2015

*Note - Items were not function tested

Insulation 29/01/2015 > 199 MOhm Pass 29/01/2016
Overall: Pass

AssetID: 126506 Description: AC ADAP Make: YAMAHA Model: NOT VISIBLE

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016

Overall: Pass

AssetID: 126507 Description: AC ADAP Make: NOT VISIBLE Model: NOT VISIBLE

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016

Overall: Pass

AssetID: 126508 Description: AC ADAP Make: NOT VISIBLE Model: 50

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016

Overall: Pass

AssetID: 126509 Description: EXT LEAD Make: PMS Model:

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.08	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	250	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016

Overall: Pass

AssetID: 126510 Description: EXT LEAD Make: ELPINE Model:

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
IEC Lead Continuity	29/01/2015	0.36	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	250	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016
IEC Lead Polarity	29/01/2015			Pass	29/01/2016

Overall: Pass

AssetID: 126573 Description: SPEAKER Make: YAMAHA Model: NOT VISIBLE

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Earth Continuity	29/01/2015	0.094	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016

Overall: Pass

AssetID: 126574 Description: SPEAKER Make: SRM Model: 0803

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Earth Continuity	29/01/2015	0.226	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	19.8	MOhm	Pass	29/01/2016

Overall: Pass

AssetID: 126575 Description: SPEAKER Make: NOT VISIBLE Model: NOT VISIBLE

User: ADAM Test Instrument: Seaward PrimeTest 350 Z39-0983 Comments

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Earth Continuity	29/01/2015	0.196	ohm	Pass	29/01/2016

Signed By:

Test Certificate



Testing Date Range From: 29/01/2015 To: 29/01/2015

***Note - Items were not function tested**

Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016

Overall: Pass

AssetID: 126576	Description: MIXER	Make: MACKIE	Model: H0174
User: ADAM	Test Instrument: Seaward PrimeTest 350 Z39-0983	Comments	

Test Type	Date	Result	Unit	Status	Next Test
Visual	29/01/2015			Pass	29/01/2016
Earth Continuity	29/01/2015	0.118	ohm	Pass	29/01/2016
Insulation Voltage	29/01/2015	500	V	Information	29/01/2016
Insulation	29/01/2015	> 199	MOhm	Pass	29/01/2016

Overall: Pass

Total Tests: 32

Signed By: