

D P Electrical

Portable Appliance Test Report

Glen Sharp 75 Cornwall Lane.

Date of Test:
 Engineer:
 Next Test Due:

25/4/13
 25/4/14
 D.P. CHAMBERLAIN

ID No	Visual Check	Voltage	Class 1 - 2	Earth Bond	Fuse Test	Insulation Test	Flash Test (Not IT Equip)	Run Leakage Test	Pass / Fail	Remarks
1	PASS	240V	1	0.03Ω	PASS	>20MΩ	PASS	PASS	PASS	Extension lead
2	PASS	240V	1	0.03Ω	"	"	"	"	"	"
3	PASS	240V	1	0.029Ω	"	"	"	"	"	"
4	PASS	240V	2	-	"	"	"	"	"	Amplifier
5	PASS	240V	2	-	"	"	"	"	"	"
6	PASS	240V	2	-	"	"	"	"	"	PA Mixer
7	PASS	240V	2	-	"	"	"	"	"	Monitor
8	PASS	240V	1	0.07Ω	"	"	"	"	"	Kettle lead
9	PASS	240V	2	-	"	"	"	"	"	Stage light
10	PASS	240V	2	-	"	"	"	"	"	Mixer
11	PASS	240V	2	-	"	"	"	"	"	power pack for minidisc player
All items passed										
										
										