

PAT4 COMPACT APPLIANCE TESTING CERTIFICATE

CLIENT AND LOCATION DETAILS

Certificate No.: 216

This form allows data to be imported from: **Megger PAT4**



Serial No.: 6410-922/010701/4046

Client Name and Address

MR M PICK
HIGHCLIFFE
THE COMMON
FRENCHAY

Location Name and Address

SMACK THE 80S
HIGHCLIFFE
THE COMMON
FRENCHAY

TEST RESULTS

Asset ID	Description	Test Date	Visual	Cont 1	Cont 2	Cont 3	Ins.	Oper.	Leak.	Extn.	Flash	Status
MP01	POWER LEAD	22/02/2015	Pass	0.055	-	-	>50	-	-	Pass	-	P
MP02	POWER LEAD	22/02/2015	Pass	0.071	-	-	>50	-	-	Pass	-	P
MP03	YAMAHA PWR PACK	22/02/2015	Pass	-	-	-	>50	0	0.17	Skip	-	P
MP04	BEHRINGER PWR PACK	22/02/2015	Pass	-	-	-	>50	0	0.3	Skip	-	P
MP05	POWER LEAD	22/02/2015	Pass	0.079	-	-	>50	-	-	Pass	-	P
MP06	KORG PWR PACK	22/02/2015	Pass	-	-	-	>50	0.013	0.17	Skip	-	P
MP07	4 WAY EXT LEAD	22/02/2015	Pass	0.125	-	-	>50	-	-	Pass	-	P
MP08	4 WAY EXT LEAD	22/02/2015	Pass	0.101	-	-	>50	-	-	Pass	-	P
MP09	4 WAY EXT LEAD	22/02/2015	Pass	0.099	-	-	>50	-	-	Pass	-	P
MP10	4 WAY EXT LEAD	22/02/2015	Pass	0.113	-	-	>50	-	-	Pass	-	P
MP11	SMOKE MACHINE	22/02/2015	Pass	0.14	-	-	>50	0.362	0.21	Skip	-	P

CONTRACTOR DETAILS

Company Name and Address

Smith & Son Electrical Ltd.
36 Grangeville Close.
Longwell Green.
Bristol.

Tester Name Neil Smith
Qualifications Technician
Position Engineer
Signature 