



Portable Appliance Testing (PAT) Results Report

Date: 12/05/15
Site: Joe Carville Pianist
Lead Engineer: Andrew McTeer
Total: 8
Bulk Retest: May-20
Doc Code: JCPAT15

| Location | Asset | Description | Date | Retest | Visual | Bond Range | Earth | EA Limit | Insulation 2 | IN2 Limit | Touch | T Limit | PN Continuity | Load | Load Limit | Current | Current Lim | Leakage | Leakage Lim | Lead Continuity | Engineer | |
|----------|-------|-----------------------|----------|--------|--------|------------|-------|----------|--------------|-----------|-------|---------|---------------|------|------------|---------|-------------|---------|-------------|-----------------|----------|-----|
| - | J1 | 5m 13A Extention Real | 11/05/15 | May-20 | P | | 0.13 | 0.2 | >299.9M | 2.0M | | | | | | | | | | | P | Amt |
| - | J2 | Behringer XYNEX PSU | 11/05/15 | May-20 | P | | | | >299.9M | 2.0M | 0 | 0.25 | P | 18VA | 3000VA | 0 | 13 | 0 | 0.25 | | | Amt |
| - | J3 | Yamaha Keyboard PSU | 11/05/15 | May-20 | P | | | | >299.9M | 2.0M | 0 | 0.25 | P | 0VA | 3000VA | 0 | 13 | 0.03 | 0.25 | | | Amt |
| - | J4 | 13A 4 Way | 11/05/15 | May-20 | P | | 0.06 | 0.1 | >299.9M | 2.0M | | | P | | | | | | | | P | Amt |
| - | J5 | IEC Lead | 11/05/15 | May-20 | P | | 0.05 | 0.1 | >299.9M | 2.0M | | | P | | | | | | | | P | Amt |
| - | J6 | JBL Powered Speaker | 11/05/15 | May-20 | P | 25A | 0 | 0.1 | >299.9M | 1.0M | | | P | 36VA | 3000VA | 0.1 | 13 | 0.95 | 3.5 | | | Amt |
| - | J7 | Ipad Charger | 11/05/15 | May-20 | P | | | | >299.9M | 2.0M | 0 | 0.25 | P | 0VA | 3000VA | 0 | 13 | 0 | 0.25 | | | Amt |
| - | J8 | Ipad Charger | 11/05/15 | May-20 | P | | | | >299.9M | 2.0M | 0 | 0.25 | P | 0VA | 3000VA | 0 | 13 | 0 | 0.25 | | | Amt |