


# Portable Appliance Testing Report



Presented to

Tested by

**Colin Wilson**

2 Ailsa Court...  
FK2 0LE

**Portable Appliance Testing  
Commencement Date**


**16/11/2018**



**Clan Electrical Partnership**

Appliances tested for electrical safety in accordance with  
the IET code of practice for in service and inspection and  
testing of electrical equipment



# Portable Appliance Test (PAT) Completion Certificate



<b>DETAILS OF THE CLIENT</b> Client and address Colin Wilson 2 Ailsa Court Maddiston Postcode: FK2 0LE		<b>ADDRESS OF TESTING</b> 2 Ailsa Court Maddiston Postcode: FK2 0LE	
<b>*ANY LIMITATIONS AGREED ON TESTING</b> *If any, reasons and with whom agreed		<b>The Premises Are:</b> Domestic <input checked="" type="checkbox"/> Commerical <input type="checkbox"/> Industrial <input type="checkbox"/>	
<b>DECLARATION</b> <p>This is to certify the electrical appliances details in this certificate and record sheets have been tested for electrical safety in accordance with the IET code of practice for in service and inspection and testing of electrical equipment. It does not guarantee the correct operation of the appliance for any length of time. Users of the appliance should be aware of any fault or defect that may occur with future use. Any doubt regarding the safety or correct operation of the appliance, the device should be removed from service for further inspection by a competent person.</p>		<b>ENGINEER, NAME &amp; SIGNATURE</b> Signature:  Name: COLIN MCMILLAN Date: 16/11/2018 	
<b>TESTING CARRIED OUT BY</b> Trading Title: <b>Clan Electrical Partnership</b> 5 Priorscroft Torphichen Bathgate Email: clanelectrical@gmail.com Web: www.clanelectrical.co.uk Telephone No: 07734591939 Postcode: EH48 4NG Registration No: 608280 Branch No:		<b>PAT TESTER SERIAL NUMBER</b> 101011876 <b>NOTES</b>	

**ANY FAILED APPLIANCES SHOULD BE REMOVED FROM SERVICE UNTIL THE DEFECT HAS BEEN RECTIFIED**

APPLIANCE SUMMARY FOR Colin Wilson 2 Ailsa Court Maddiston FK2 0LE

Total Appliances

21

Appliances Passed

23

Appliances Failed

0

PORTABLE APPLIANCE REGISTER

Appliance number	Appliance	Class	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection (months)	Combined Inspection & Test (months)	Result
					Earth continuity test ( $\Omega$ )	Insulation Resistance M( $\Omega$ )	Load test (kVA)	Earth Leakage Test (mA)					
1	Sansamp 1 Preamp	1	Mobile	1	0.04	>200	N/A	N/A	✓	3	3	12	Pass
2	Sansamp 2 Preamp	1	Mobile	2	0.04	200	N/A	N/A	✓	5	3	12	Pass
3	Digital Tuner	1	Mobile	3	0.04	>200	N/A	N/A	✓	5	3	12	Pass
4	DB Monitor 1	1	Mobile	4	0.04	>200	N/A	N/A	✓	13	3	12	Pass
5	DB Monitor 2	1	Mobile	5	0.04	>200	N/A	N/A	✓	13	3	12	Pass
6	Radio Mic	3	Mobile	6	N/A	>200	N/A	N/A	✓	N/A	3	12	Pass
7	CD Player	2	Mobile	7	0.04	>200	N/A	N/A	✓	3	3	12	Pass
8	Power Strip	1	Mobile	8	0.04	>200	N/A	N/A	✓	13	3	12	Pass
9	Pre Amp	1	Mobile	9	0.04	>200	N/A	N/A	✓		3	12	Pass
10	Reverb	1	Mobile	9	0.04	>200	N/A	N/A	✓		3	12	Pass
11	Equaliser	1	Mobile	10	0.04	>200	N/A	N/A	✓		3	12	Pass
12	Mixing Desk	1	Mobile	12	0.04	>200	N/A	N/A	✓		3	12	Pass
13	Powered Speaker 1	1	Mobile	13	0.04	>200	N/A	N/A	✓	13	3	12	Pass
14	Powered Speaker 2	1	Mobile	14	0.04	>200	N/A	N/A	✓	13	3	12	Pass
15	Bass Amp	1	Mobile	15	0.05	>200	N/A	N/A	✓	5	3	12	Pass
16	4 Light Rig	1	Mobile	16	0.04	>200	N/A	N/A	✓	5	3	12	Pass

Appliance number	Appliance	Class	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection (months)	Combined Inspection & Test (months)	Result
					Earth continuity test ( $\Omega$ )	Insulation Resistance M( $\Omega$ )	Load test (kVA)	Earth Leakage Test (mA)					
17	6 Point Extension Lead	1	Mobile	1	0.04	>200	N/A	N/A	✓	13	3	12	Pass
18	4 Point Extension Lead	1	Mobile	18	0.04	>200	N/A	N/A	✓	13	3	12	Pass
19	2 Point Extension Lead	1	Mobile	19	0.04	>200	N/A	N/A	✓	13	3	12	Pass
20	DB Monitor 3	1	Mobile	20	0.04	>200	N/A	N/A	✓	13	3	12	Pass
21	Radio Mic 2	3	Mobile	21	N/A	N/A	N/A	N/A	✓	N/A	3	12	Pass