

Concise Latest Test Results



Page 1
Monday, 18. November 2013 16:22

Test Status: All, Test Type: All
Person: All, Instrument: All

Client:		Site: PAUL		Location: WORCESTER			
Asset ID	Description	User	Test Instrument	Date	Retest Period	Next Test	Result
117	LAMP	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
118	PSU	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
119	EXTENTION	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
120	IEC	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
121	EXT	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
122	IEC	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
123	IEC	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
124	IEC	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
125	PSU	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
126	PSU	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
127	IEC	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
128	PSU	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
129	IEC	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
130	PSU	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
131	IEC	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
132	PSU	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass
133	IEC	GW	35A-0488	18/11/2013	12 Months	18/11/2014	Pass

Total Tests: 17

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All

Client: PAUL		Location: WORCESTER			
Asset ID: 117	Description: LAMP	User: GW	Test Instrument: 35A-0488		
Test Type	Date	Result	Unit	Status	
Visual	18/11/2013			Pass	
Insulation Voltage	18/11/2013	500	V	Information	
Insulation	18/11/2013	> 199	MOhm	Pass	
Overall: Pass					
Asset ID: 118	Description: PSU	User: GW	Test Instrument: 35A-0488		
Test Type	Date	Result	Unit	Status	
Visual	18/11/2013			Pass	
Insulation Voltage	18/11/2013	500	V	Information	
Insulation	18/11/2013	> 199	MOhm	Pass	
Overall: Pass					
Asset ID: 119	Description: EXTENTION	User: GW	Test Instrument: 35A-0488		
Test Type	Date	Result	Unit	Status	
Visual	18/11/2013			Pass	
IEC Lead Continuity	18/11/2013	0.126	ohm	Pass	
Insulation Voltage	18/11/2013	500	V	Information	
Insulation	18/11/2013	> 199	MOhm	Pass	
IEC Lead Polarity	18/11/2013			Pass	
Overall: Pass					
Asset ID: 120	Description: IEC	User: GW	Test Instrument: 35A-0488		
Test Type	Date	Result	Unit	Status	
Visual	18/11/2013			Pass	
IEC Lead Continuity	18/11/2013	0.09	ohm	Pass	
Insulation Voltage	18/11/2013	500	V	Information	
Insulation	18/11/2013	> 199	MOhm	Pass	
IEC Lead Polarity	18/11/2013			Pass	
Overall: Pass					
Asset ID: 121	Description: EXT	User: GW	Test Instrument: 35A-0488		
Test Type	Date	Result	Unit	Status	
Visual	18/11/2013			Pass	
IEC Lead Continuity	18/11/2013	0.262	ohm	Pass	
Insulation Voltage	18/11/2013	500	V	Information	
Insulation	18/11/2013	> 199	MOhm	Pass	
IEC Lead Polarity	18/11/2013			Pass	
Overall: Pass					
Asset ID: 122	Description: IEC	User: GW	Test Instrument: 35A-0488		
Test Type	Date	Result	Unit	Status	
Visual	18/11/2013			Pass	
IEC Lead Continuity	18/11/2013	0.082	ohm	Pass	
Insulation Voltage	18/11/2013	500	V	Information	
Insulation	18/11/2013	> 199	MOhm	Pass	
IEC Lead Polarity	18/11/2013			Pass	
Overall: Pass					
Asset ID: 123	Description: IEC	User: GW	Test Instrument: 35A-0488		
Test Type	Date	Result	Unit	Status	
Visual	18/11/2013			Pass	
IEC Lead Continuity	18/11/2013	0.092	ohm	Pass	
Insulation Voltage	18/11/2013	500	V	Information	
Insulation	18/11/2013	> 199	MOhm	Pass	
IEC Lead Polarity	18/11/2013			Pass	
Overall: Pass					
Asset ID: 124	Description: IEC	User: GW	Test Instrument: 35A-0488		
Test Type	Date	Result	Unit	Status	
Visual	18/11/2013			Pass	
Insulation Voltage	18/11/2013	500	V	Information	
Insulation	18/11/2013	> 199	MOhm	Pass	
Overall: Pass					
Asset ID: 125	Description: PSU	User: GW	Test Instrument: 35A-0488		
Test Type	Date	Result	Unit	Status	
Visual	18/11/2013			Pass	
Insulation Voltage	18/11/2013	500	V	Information	

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All

Insulation 18/11/2013 > 199 MOhm Pass
Overall: Pass

Asset ID: 126 Description: PSU User: GW Test Instrument: 35A-0488

Test Type	Date	Result	Unit	Status
Visual	18/11/2013			Pass
Insulation Voltage	18/11/2013	500	V	Information
Insulation	18/11/2013	> 199	MOhm	Pass

Overall: Pass

Asset ID: 127 Description: IEC User: GW Test Instrument: 35A-0488

Test Type	Date	Result	Unit	Status
Visual	18/11/2013			Pass
Insulation Voltage	18/11/2013	500	V	Information
Insulation	18/11/2013	> 199	MOhm	Pass

Overall: Pass

Asset ID: 128 Description: PSU User: GW Test Instrument: 35A-0488

Test Type	Date	Result	Unit	Status
Visual	18/11/2013			Pass
Insulation Voltage	18/11/2013	500	V	Information
Insulation	18/11/2013	> 199	MOhm	Pass

Overall: Pass

Asset ID: 129 Description: IEC User: GW Test Instrument: 35A-0488

Test Type	Date	Result	Unit	Status
Visual	18/11/2013			Pass
IEC Lead Continuity	18/11/2013	0.052	ohm	Pass
Insulation Voltage	18/11/2013	500	V	Information
Insulation	18/11/2013	> 199	MOhm	Pass
IEC Lead Polarity	18/11/2013			Pass

Overall: Pass

Asset ID: 130 Description: PSU User: GW Test Instrument: 35A-0488

Test Type	Date	Result	Unit	Status
Visual	18/11/2013			Pass
Insulation Voltage	18/11/2013	500	V	Information
Insulation	18/11/2013	> 199	MOhm	Pass

Overall: Pass

Asset ID: 131 Description: IEC User: GW Test Instrument: 35A-0488

Test Type	Date	Result	Unit	Status
Visual	18/11/2013			Pass
IEC Lead Continuity	18/11/2013	0.094	ohm	Pass
Insulation Voltage	18/11/2013	500	V	Information
Insulation	18/11/2013	> 199	MOhm	Pass
IEC Lead Polarity	18/11/2013			Pass

Overall: Pass

Asset ID: 132 Description: PSU User: GW Test Instrument: 35A-0488

Test Type	Date	Result	Unit	Status
Visual	18/11/2013			Pass
Insulation Voltage	18/11/2013	500	V	Information
Insulation	18/11/2013	> 199	MOhm	Pass

Overall: Pass

Asset ID: 133 Description: IEC User: GW Test Instrument: 35A-0488

Test Type	Date	Result	Unit	Status
Visual	18/11/2013			Pass
IEC Lead Continuity	18/11/2013	0.106	ohm	Pass
Insulation Voltage	18/11/2013	500	V	Information
Insulation	18/11/2013	> 199	MOhm	Pass
IEC Lead Polarity	18/11/2013			Pass

Overall: Pass

Total Tests: 17