

Test Certificate



Testing Date Range From: 26/11/2013 To: 26/11/2013
*Note - Items were not function tested

Client: Alex Pick		Site: 103 Tivoli Cr		Location: GARAGE	
Asset ID: 84070	Description: IEC LEAD		Make: LONGWELL	Model: LS60	
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments		
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.12	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					
Asset ID: 84071	Description: EQUALIZER		Make: BEHRINGER	Model: 3102	
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments		
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
Earth Continuity	26/11/2013	0.216	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
Overall: Pass					
Asset ID: 84072	Description: 4 WAY EXT LEAD		Make: HONG YI	Model: NA	
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments		
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.146	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					
Asset ID: 84073	Description: 2 WAY EXT LEAD		Make: OMEGA	Model: NA	
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments		
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.244	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					
Asset ID: 84074	Description: 4 WAY EXT LEAD		Make: HOMEBASE	Model: NA	
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments		
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.168	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					
Asset ID: 84075	Description: IEC LEAD		Make: CDC	Model: NA	
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments		
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.1	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					
Asset ID: 84076	Description: IEC LEAD		Make: NA	Model: NA	
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments		
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.148	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

PAT Central Ltd, Suite 12648, 2nd Floor, 145-157 St John Street, London, EC1V 4PY
Tel: 08006124879 Email: info@patcentral.co.uk

Signed By:

Test Certificate



Testing Date Range From: 26/11/2013 To: 26/11/2013
*Note - Items were not function tested

Asset ID: 84077	Description: IEC LEAD	Make: VOLEX	Model: V1625			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments			
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
IEC Lead Continuity		26/11/2013	0.13	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity		26/11/2013			Pass	26/11/2014
Overall: Pass						

Asset ID: 84078	Description: IEC LEAD	Make: NA	Model: QT3			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments			
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
IEC Lead Continuity		26/11/2013	0.088	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity		26/11/2013			Pass	26/11/2014
Overall: Pass						

Asset ID: 84079	Description: 4 WAY EXT LEAD	Make: PERMAPLUG	Model: NA			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments			
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
IEC Lead Continuity		26/11/2013	0.242	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity		26/11/2013			Pass	26/11/2014
Overall: Pass						

Asset ID: 84080	Description: 2 WAY EXT LEAD	Make: OMEGA	Model: NA			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments			
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
IEC Lead Continuity		26/11/2013	0.192	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	250	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity		26/11/2013			Pass	26/11/2014
Overall: Pass						

Asset ID: 84081	Description: IEC LEAD	Make: YUNG LI	Model: YC-12			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments			
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
IEC Lead Continuity		26/11/2013	0.092	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity		26/11/2013			Pass	26/11/2014
Overall: Pass						

Asset ID: 84082	Description: 4 WAY EXT LEAD	Make: HOMEBASE	Model: NA			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments			
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
IEC Lead Continuity		26/11/2013	0.146	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity		26/11/2013			Pass	26/11/2014
Overall: Pass						

Asset ID: 84083	Description: 2 WAY EXT LEAD	Make: OMEGA	Model: NA			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments			
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
IEC Lead Continuity		26/11/2013	0.19	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	250	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity		26/11/2013			Pass	26/11/2014
Overall: Pass						

PAT Central Ltd, Suite 12648, 2nd Floor, 145-157 St John Street, London, EC1V 4PY
Tel: 08006124879 Email: info@patcentral.co.uk

Signed By:

Test Certificate



Testing Date Range From: 26/11/2013 To: 26/11/2013
*Note - Items were not function tested

Asset ID: 84084	Description: IEC LEAD	Make: NA	Model: NA		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.11	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84085	Description: IEC LEAD	Make: KING CORD	Model: KC-003		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.104	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84086	Description: IEC LEAD	Make: ISHENG	Model: IS14		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.102	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84087	Description: IEC LEAD	Make: SHENG YI	Model: NA		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.094	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84088	Description: 4 WAY EXT LEAD	Make: TESCO	Model: NA		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.262	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84138	Description: IEC LEAD	Make: HP	Model: HC10		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.11	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84139	Description: IEC LEAD	Make: LEE YUEN	Model: NA		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.096	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Signed By:

Test Certificate



Testing Date Range From: 26/11/2013 To: 26/11/2013
*Note - Items were not function tested

Asset ID: 84140	Description: IEC LEAD	Make: CDC	Model: NA			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
IEC Lead Continuity		26/11/2013	0.09	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity		26/11/2013			Pass	26/11/2014
Overall: Pass						

Asset ID: 84141	Description: IEC LEAD	Make: NA	Model: NA		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.122	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84142	Description: IEC LEAD	Make: NA	Model: NA			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
IEC Lead Continuity		26/11/2013	0.082	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity		26/11/2013			Pass	26/11/2014
Overall: Pass						

Asset ID: 84143	Description: AC ADAPTOR	Make: SHURE	Model: PS21UK		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
Overall: Pass					

Asset ID: 84144	Description: IEC LEAD	Make: LONGWELL	Model: LS60		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.106	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84145	Description: IEC LEAD	Make: KENIC	Model: NA			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
IEC Lead Continuity		26/11/2013	0.112	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity		26/11/2013			Pass	26/11/2014
Overall: Pass						

Asset ID: 84146	Description: IEC LEAD	Make: CDC	Model: NA		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.114	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Signed By:

Test Certificate



Testing Date Range From: 26/11/2013 To: 26/11/2013
*Note - Items were not function tested

Asset ID: 84147	Description: IEC LEAD	Make: NA	Model: NA		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.114	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84148	Description: IEC LEAD	Make: ISHENG	Model: IS14		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.1	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84149	Description: IEC LEAD	Make: NA	Model: NA		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.1	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84150	Description: IEC LEAD	Make: ISHENG	Model: IS14			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
IEC Lead Continuity		26/11/2013	0.104	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity		26/11/2013			Pass	26/11/2014
Overall: Pass						

Asset ID: 84151	Description: IEC LEAD	Make: NA	Model: NA		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
IEC Lead Continuity	26/11/2013	0.108	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014
IEC Lead Polarity	26/11/2013			Pass	26/11/2014
Overall: Pass					

Asset ID: 84152	Description: SPEAKER	Make: MACKIE	Model: 1521		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
Earth Continuity	26/11/2013	0.156	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	105	MOhm	Pass	26/11/2014
Overall: Pass					

Asset ID: 84153	Description: SPEAKER	Make: MACKIE	Model: SRM350		
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments			
Test Type	Date	Result	Unit	Status	Next Test
Visual	26/11/2013			Pass	26/11/2014
Earth Continuity	26/11/2013	0.166	ohm	Pass	26/11/2014
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014
Insulation	26/11/2013	115	MOhm	Pass	26/11/2014
Overall: Pass					

Signed By:

Test Certificate



Testing Date Range From: 26/11/2013 To: 26/11/2013
*Note - Items were not function tested

Asset ID: 84154	Description: SPEAKER	Make: MACKIE	Model: SRM450			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type	Date	Result	Unit	Status	Next Test	
Visual	26/11/2013			Pass	26/11/2014	
Earth Continuity	26/11/2013	0.126	ohm	Pass	26/11/2014	
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014	
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014	
Overall: Pass						

Asset ID: 84155	Description: IEC LEAD	Make: NA	Model: NA			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type	Date	Result	Unit	Status	Next Test	
Visual	26/11/2013			Pass	26/11/2014	
IEC Lead Continuity	26/11/2013	0.122	ohm	Pass	26/11/2014	
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014	
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014	
IEC Lead Polarity	26/11/2013			Pass	26/11/2014	
Overall: Pass						

Asset ID: 84156	Description: LIGHTS	Make: KAM	Model: PARTY BAR			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
Earth Continuity		26/11/2013	0.14	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
Overall: Pass						

Asset ID: 84157	Description: LIGHTS	Make: KAM	Model: PARTY BAR			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type	Date	Result	Unit	Status	Next Test	
Visual	26/11/2013			Pass	26/11/2014	
Earth Continuity	26/11/2013	0.152	ohm	Pass	26/11/2014	
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014	
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014	
Overall: Pass						

Asset ID: 84158	Description: SPEAKER	Make: MACKIE	Model: SRM450			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type	Date	Result	Unit	Status	Next Test	
Visual	26/11/2013			Pass	26/11/2014	
Earth Continuity	26/11/2013	0.132	ohm	Pass	26/11/2014	
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014	
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014	
Overall: Pass						

Asset ID: 84159	Description: SPEAKER	Make: MACKIE	Model: SRM450			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type	Date	Result	Unit	Status	Next Test	
Visual	26/11/2013			Pass	26/11/2014	
Earth Continuity	26/11/2013	0.184	ohm	Pass	26/11/2014	
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014	
Insulation	26/11/2013	23	MOhm	Pass	26/11/2014	
Overall: Pass						

Asset ID: 84160	Description: SPEAKER	Make: MACKIE	Model: SRM450			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type	Date	Result	Unit	Status	Next Test	
Visual	26/11/2013			Pass	26/11/2014	
Earth Continuity	26/11/2013	0.14	ohm	Pass	26/11/2014	
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014	
Insulation	26/11/2013	31	MOhm	Pass	26/11/2014	
Overall: Pass						

Asset ID: 84161	Description: LIGHTS	Make: KAM	Model: PARTY BAR			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517	Comments				
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
Earth Continuity		26/11/2013	0.124	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014

PAT Central Ltd, Suite 12648, 2nd Floor, 145-157 St John Street, London, EC1V 4PY
Tel: 08006124879 Email: info@patcentral.co.uk

Signed By:

Test Certificate



Testing Date Range From: 26/11/2013 To: 26/11/2013
*Note - Items were not function tested

Insulation 26/11/2013 > 199 MOhm Pass 26/11/2014
Overall: Pass

Asset ID: 84162	Description: SPEAKER	Make: MACKIE	Model: 1521			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments			
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
Earth Continuity		26/11/2013	0.134	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
Overall: Pass						

AssetID: 84163	Description: 2 WAY EXT LEAD	Make: CONNEXION	Model: NA			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments			
Test Type	Date	Result	Unit	Status	Next Test	
Visual	26/11/2013			Pass	26/11/2014	
IEC Lead Continuity	26/11/2013	0.476	ohm	Pass	26/11/2014	
Insulation Voltage	26/11/2013	500	V	Information	26/11/2014	
Insulation	26/11/2013	> 199	MOhm	Pass	26/11/2014	
IEC Lead Polarity	26/11/2013			Pass	26/11/2014	
Overall: Pass						

Asset ID: 84164	Description: SUB	Make: MACKIE	Model: 1801			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments			
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
Earth Continuity		26/11/2013	0.156	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
Overall: Pass						

Asset ID: 84165	Description: SPEAKER	Make: MACKIE	Model: 1801			
User: BRENT	Test Instrument: Seaward PrimeTest 350 35A-0517		Comments			
Test Type		Date	Result	Unit	Status	Next Test
Visual		26/11/2013			Pass	26/11/2014
Earth Continuity		26/11/2013	0.242	ohm	Pass	26/11/2014
Insulation Voltage		26/11/2013	500	V	Information	26/11/2014
Insulation		26/11/2013	> 199	MOhm	Pass	26/11/2014
Overall: Pass						

Total Tests: 47

Signed By: