

Form V.2 Equipment formal visual and combined inspection and test record

Inspector (Note 1)	Name:	R. SANT	Client: (Note 2)	Murphy James 8 Redwood Gdns. Slough SL3 30T		
	Organization:	ABBEEY FIELD				
	Date:	31-7-14				
Item		Note	Item 1	Item 2	Item 3	Item 4
Equipment ID No.		3	POWER			
Description		4	MIXER			
Construction Class		5	II			
Type (S, IT, M, P, H, F)		6	M			
Location		7				
Frequency	Formal Visual Insp.	8	✓			
	Combined Inspection & Test	9	12 Mths			
Make		10	STWARD			
Model			MASTER			
Serial No.						
Voltage (V) (if different from 230 V)		11				
Rating (watts or A)		12				
Fuse (A)		13	13			
Condition of: (✓ or ✗)	Socket-outlet	14	✓			
	Plug	14	✓			
	Flex	14	✓			
	Body	14	✓			
	Other (please state)	14				
Test Results	Continuity (Ω)	15(i)	0.10			
	Insulation Resistance (MΩ)	15(ii)	>200			
	Polarity ✓ or ✗	15(iii)	✓			
	Function ✓ or ✗	15(iv)	✓			
	Other (please state)	15(v)				
Suitable for environment (Y or N)		16	Y			
Comments		17				
Suitable for continued use (Y or N)		18	Y			
Initials		19	RS			



Note: (✓) indicates pass, (✗) indicates fail, (N/A) not applicable, (N/C) not checked