

Test Certificate



Testing Date Range From: 02/01/2014 To: 02/01/2014
*Note - Items were not function tested

| | | |
|-----------------------------|--------------------------------------------------------|---------------------------|
| Client: Tim Sentance | Site: 3Bramcote Grove | Location: MUSIC RM |
| Asset ID: 86916 | Description: AMPLIFIER | Make: ROLAND |
| User: BRENT | Test Instrument: Seaward PrimeTest 350 35A-0517 | Model: KC-350 |
| Comments: | | |

| Test Type | Date | Result | Unit | Status | Next Test |
|--------------------|------------|--------|------|-------------|------------|
| Visual | 02/01/2014 | | | Pass | 02/01/2015 |
| Earth Continuity | 02/01/2014 | 0.206 | ohm | Pass | 02/01/2015 |
| Insulation Voltage | 02/01/2014 | 500 | V | Information | 02/01/2015 |
| Insulation | 02/01/2014 | > 199 | MOhm | Pass | 02/01/2015 |
| Overall: Pass | | | | | |

| | | | |
|------------------------|--------------------------------------------------------|-----------------------|------------------|
| Asset ID: 86917 | Description: IEC LEAD | Make: LEE YUEN | Model: NA |
| User: BRENT | Test Instrument: Seaward PrimeTest 350 35A-0517 | Comments: | |

| Test Type | Date | Result | Unit | Status | Next Test |
|---------------------|------------|--------|------|-------------|------------|
| Visual | 02/01/2014 | | | Pass | 02/01/2015 |
| IEC Lead Continuity | 02/01/2014 | 0.102 | ohm | Pass | 02/01/2015 |
| Insulation Voltage | 02/01/2014 | 500 | V | Information | 02/01/2015 |
| Insulation | 02/01/2014 | > 199 | MOhm | Pass | 02/01/2015 |
| IEC Lead Polarity | 02/01/2014 | | | Pass | 02/01/2015 |
| Overall: Pass | | | | | |

| | | | |
|------------------------|--------------------------------------------------------|---------------------|--------------------------|
| Asset ID: 86918 | Description: KEYBOARD | Make: ROLAND | Model: JUPITER-80 |
| User: BRENT | Test Instrument: Seaward PrimeTest 350 35A-0517 | Comments: | |

| Test Type | Date | Result | Unit | Status | Next Test |
|--------------------|------------|--------|------|-------------|------------|
| Visual | 02/01/2014 | | | Pass | 02/01/2015 |
| Earth Continuity | 02/01/2014 | 0.186 | ohm | Pass | 02/01/2015 |
| Insulation Voltage | 02/01/2014 | 500 | V | Information | 02/01/2015 |
| Insulation | 02/01/2014 | > 199 | MOhm | Pass | 02/01/2015 |
| Overall: Pass | | | | | |

| | | | |
|------------------------|--------------------------------------------------------|------------------|-----------------------|
| Asset ID: 86919 | Description: IEC LEAD | Make: NA | Model: MSL-107 |
| User: BRENT | Test Instrument: Seaward PrimeTest 350 35A-0517 | Comments: | |

| Test Type | Date | Result | Unit | Status | Next Test |
|---------------------|------------|--------|------|-------------|------------|
| Visual | 02/01/2014 | | | Pass | 02/01/2015 |
| IEC Lead Continuity | 02/01/2014 | 0.11 | ohm | Pass | 02/01/2015 |
| Insulation Voltage | 02/01/2014 | 500 | V | Information | 02/01/2015 |
| Insulation | 02/01/2014 | > 199 | MOhm | Pass | 02/01/2015 |
| IEC Lead Polarity | 02/01/2014 | | | Pass | 02/01/2015 |
| Overall: Pass | | | | | |

| | | | |
|------------------------|--------------------------------------------------------|-------------------|--------------------|
| Asset ID: 86920 | Description: KEYBOARD | Make: KORG | Model: SV-1 |
| User: BRENT | Test Instrument: Seaward PrimeTest 350 35A-0517 | Comments: | |

| Test Type | Date | Result | Unit | Status | Next Test |
|--------------------|------------|--------|------|-------------|------------|
| Visual | 02/01/2014 | | | Pass | 02/01/2015 |
| Earth Continuity | 02/01/2014 | 0.164 | ohm | Pass | 02/01/2015 |
| Insulation Voltage | 02/01/2014 | 500 | V | Information | 02/01/2015 |
| Insulation | 02/01/2014 | > 199 | MOhm | Pass | 02/01/2015 |
| Overall: Pass | | | | | |

Total Tests: 5

Signed By:

Detailed Asset List



| Client: Tim Sentance | | Site: 3Bramcote Grove | | | Location: MUSIC RM | | | |
|----------------------|-------------|-----------------------|------------|-----------|--------------------|------------|-------------|-------------|
| Asset ID | Description | Make | Model | Serial No | Last Test | Next Test | Last Visual | Next Visual |
| 86916 | AMPLIFIER | ROLAND | KC-350 | 9107 | 02/01/2014 | 02/01/2015 | 02/01/2014 | |
| 86917 | IEC LEAD | LEE YUEN | NA | NA | 02/01/2014 | 02/01/2015 | 02/01/2014 | |
| 86918 | KEYBOARD | ROLAND | JUPITER-80 | 2951 | 02/01/2014 | 02/01/2015 | 02/01/2014 | |
| 86919 | IEC LEAD | NA | MSL-107 | NA | 02/01/2014 | 02/01/2015 | 02/01/2014 | |
| 86920 | KEYBOARD | KORG | SV-1 | NA | 02/01/2014 | 02/01/2015 | 02/01/2014 | |
| Total Assets: 5 | | | | | | | | |