

# Test Certificate



Testing Date RangeFrom: 16/01/2017 To: 16/01/2017  
\*Note - Items were not function tested

Client: Leo Mantini		Site: 37 Seymour Road		Location: LOUNGE	
Asset ID: 162843	Description: EXTN	Make:		Model:	
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020		Comments:		
Test Type	Date	Result	Unit	Status	
Plug	16/01/2017			Pass	
Flex	16/01/2017			Pass	
Enclosure	16/01/2017			Pass	
Environment	16/01/2017			Pass	
Socket	16/01/2017			Pass	
Switch	16/01/2017			Pass	
Voltage	16/01/2017	230	V	Information	
IEC Lead Continuity	16/01/2017	0.34	ohm	Pass	
Insulation Voltage	16/01/2017	500	V	Information	
Insulation	16/01/2017	> 19.99	MOhm	Pass	
IEC Lead Polarity	16/01/2017			Pass	
Overall: Pass					

Asset ID: 162844		Description: EXTN		Make:		Model:	
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020		Comments:				
Test Type	Date	Result	Unit	Status			
Plug	16/01/2017			Pass			
Flex	16/01/2017			Pass			
Enclosure	16/01/2017			Pass			
Environment	16/01/2017			Pass			
Socket	16/01/2017			Pass			
Switch	16/01/2017			Pass			
Voltage	16/01/2017	230	V	Information			
IEC Lead Continuity	16/01/2017	0.34	ohm	Pass			
Insulation Voltage	16/01/2017	500	V	Information			
Insulation	16/01/2017	> 19.99	MOhm	Pass			
IEC Lead Polarity	16/01/2017			Pass			
Overall: Pass							

Asset ID: 162845		Description: EXTN		Make:		Model:	
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020		Comments:				
Test Type	Date	Result	Unit	Status			
Plug	16/01/2017			Pass			
Flex	16/01/2017			Pass			
Enclosure	16/01/2017			Pass			
Environment	16/01/2017			Pass			
Socket	16/01/2017			Pass			
Switch	16/01/2017			Pass			
Voltage	16/01/2017	230	V	Information			
IEC Lead Continuity	16/01/2017	0.33	ohm	Pass			
Insulation Voltage	16/01/2017	500	V	Information			
Insulation	16/01/2017	> 19.99	MOhm	Pass			
IEC Lead Polarity	16/01/2017			Pass			
Overall: Pass							

Asset ID: 162846		Description: EXTN		Make:		Model:	
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020		Comments:				
Test Type	Date	Result	Unit	Status			
Plug	16/01/2017			Pass			
Flex	16/01/2017			Pass			
Enclosure	16/01/2017			Pass			
Environment	16/01/2017			Pass			
Socket	16/01/2017			Pass			
Switch	16/01/2017			Pass			
Voltage	16/01/2017	230	V	Information			
IEC Lead Continuity	16/01/2017	0.32	ohm	Pass			
Insulation Voltage	16/01/2017	500	V	Information			
Insulation	16/01/2017	> 19.99	MOhm	Pass			
IEC Lead Polarity	16/01/2017			Pass			
Overall: Pass							

Asset ID: 162847		Description: EXTN		Make:		Model:	
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020		Comments:				
Test Type	Date	Result	Unit	Status			
Plug	16/01/2017			Pass			
Flex	16/01/2017			Pass			
Enclosure	16/01/2017			Pass			

Signed By:



# Test Certificate



Testing Date Range From: 16/01/2017 To: 16/01/2017  
\*Note - Items were not function tested

Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
IEC Lead Continuity	16/01/2017	0.32	ohm	Pass
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	16/01/2017			Pass

Overall: Pass

Asset ID: 162848	Description: EXTN	Make:	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
IEC Lead Continuity	16/01/2017	0.32	ohm	Pass
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	16/01/2017			Pass

Overall: Pass

Asset ID: 162849	Description: EXTN	Make:	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
IEC Lead Continuity	16/01/2017	0.32	ohm	Pass
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	16/01/2017			Pass

Overall: Pass

Asset ID: 162850	Description: IEC LEAD	Make:	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
IEC Lead Continuity	16/01/2017	0.08	ohm	Pass
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	16/01/2017			Pass

Overall: Pass

Asset ID: 162851	Description: IEC LEAD	Make:	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
IEC Lead Continuity	16/01/2017	0.07	ohm	Pass
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	16/01/2017			Pass

Signed By:



# Test Certificate



Testing Date RangeFrom: 16/01/2017 To: 16/01/2017  
\*Note - Items were not function tested

Overall: Pass

Asset ID: 162852	Description: IEC LEAD	Make:	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
IEC Lead Continuity	16/01/2017	0.06	ohm	Pass
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	16/01/2017			Pass

Overall: Pass

Asset ID: 162853	Description: IEC LEAD	Make:	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
IEC Lead Continuity	16/01/2017	0.09	ohm	Pass
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	16/01/2017			Pass

Overall: Pass

Asset ID: 162854	Description: IEC LEAD	Make:	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
IEC Lead Continuity	16/01/2017	0.07	ohm	Pass
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	16/01/2017			Pass

Overall: Pass

Asset ID: 162855	Description: IEC LEAD	Make:	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
IEC Lead Continuity	16/01/2017	0.11	ohm	Pass
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	16/01/2017			Pass

Overall: Pass

Asset ID: 162856	Description: SPEAKERS	Make: OPERA	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass

Signed By:



# Test Certificate



Testing Date Range From: 16/01/2017 To: 16/01/2017  
**\*Note - Items were not function tested**

Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 162857	Description: SPEAKERS	Make: OPERA	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 162858	Description: SPEAKERS	Make: SRM	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 162859	Description: SPEAKERS	Make: SRM	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 162860	Description: SPEAKERS	Make: OPERA	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 162861	Description: DJ MIXER	Make: PRO FX	Model:
User: JAY	Test Instrument: Seaward Apollo 600 03H-0020	Comments:	

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass

Signed By:



# Test Certificate



Testing Date RangeFrom: 16/01/2017 To: 16/01/2017

**\*Note - Items were not function tested**

Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 162862    Description: AC ADAPTER    Make: BEHRINGER    Model:

User: JAY    Test Instrument: Seaward Apollo 600 03H-0020    Comments:

Test Type	Date	Result	Unit	Status
Plug	16/01/2017			Pass
Flex	16/01/2017			Pass
Enclosure	16/01/2017			Pass
Environment	16/01/2017			Pass
Socket	16/01/2017			Pass
Switch	16/01/2017			Pass
Voltage	16/01/2017	230	V	Information
Insulation Voltage	16/01/2017	500	V	Information
Insulation	16/01/2017	> 19.99	MOhm	Pass

Overall: Pass

User: JAY    Test Instrument: Seaward Apollo 600 03H-0020    Comments:

Total Tests: 20

Signed By:

