

Test Certificate

Testing Date RangeFrom: 10/09/2015 To: 10/09/2015

*Note - Items were not function tested

Client: John Cervantes **Site:** 3Hunters Meadow **Location:** FLAT

Asset ID: 84021 Description: IEC LEAD Make: Model:

User: JAY Test Instrument: Seaward PrimeTest 350 18B-0322 Comments:

Test Type	Date	Result	Unit	Status
Visual	10/09/2015			Pass
IEC Lead Continuity	10/09/2015	0.108	ohm	Pass
Insulation Voltage	10/09/2015	500	V	Information
Insulation	10/09/2015	52	MOhm	Pass
IEC Lead Polarity	10/09/2015			Pass

Overall: Pass

Asset ID: 84022 Description: EXTN Make: Model:

User: JAY Test Instrument: Seaward PrimeTest 350 18B-0322 Comments:

Test Type	Date	Result	Unit	Status
Visual	10/09/2015			Pass
IEC Lead Continuity	10/09/2015	0.672	ohm	Pass
Insulation Voltage	10/09/2015	500	V	Information
Insulation	10/09/2015	26	MOhm	Pass
IEC Lead Polarity	10/09/2015			Pass

Overall: Pass

Asset ID: 84023 Description: EXTN Make: Model:

User: JAY Test Instrument: Seaward PrimeTest 350 18B-0322 Comments:

Test Type	Date	Result	Unit	Status
Visual	10/09/2015			Pass
IEC Lead Continuity	10/09/2015	0.676	ohm	Pass
Insulation Voltage	10/09/2015	500	V	Information
Insulation	10/09/2015	82	MOhm	Pass
IEC Lead Polarity	10/09/2015			Pass

Overall: Pass

Asset ID: 84024 Description: SPEAKERS Make: SRM Model: 2950

User: JAY Test Instrument: Seaward PrimeTest 350 18B-0322 Comments:

Test Type	Date	Result	Unit	Status
Visual	10/09/2015			Pass
Insulation Voltage	10/09/2015	500	V	Information
Insulation	10/09/2015	49	MOhm	Pass

Overall: Pass

Asset ID: 84025 Description: KEYBOARD Make: KORG Model: 1218

User: JAY Test Instrument: Seaward PrimeTest 350 18B-0322 Comments:

Test Type	Date	Result	Unit	Status
Visual	10/09/2015			Pass
Insulation Voltage	10/09/2015	500	V	Information
Insulation	10/09/2015	66	MOhm	Pass

Overall: Pass

Asset ID: 84026 Description: 2 CORE LEAD Make: Model:

User: JAY Test Instrument: Seaward PrimeTest 350 18B-0322 Comments:

Test Type	Date	Result	Unit	Status
Visual	10/09/2015			Pass
Insulation Voltage	10/09/2015	500	V	Information
Insulation	10/09/2015	67	MOhm	Pass

Overall: Pass

User: JAY Test Instrument: Seaward PrimeTest 350 18B-0322 Comments:

Total Tests: 6

Signed By:



PAT Central Ltd, 20-22 Wenlock Road, London, N1 7GU
Tel: 08006124879 Email: info@patcentral.co.uk

