

# Test Certificate



Testing Date RangeFrom: 13/07/2015 To: 16/07/2015

\*Note - Items were not function tested

<b>Client:</b> David Guzman	<b>Site:</b> 20-21 Leighton	<b>Location:</b> FLAT
Asset ID: 142049	Description: IEC LEAD	Make:
User: ADAM	Test Instrument: Seaward PrimeTest 350 29A-0467	Comments:

Test Type	Date	Result	Unit	Status
Visual	15/07/2015			Pass
IEC Lead Continuity	15/07/2015	0.144	ohm	Pass
Insulation Voltage	15/07/2015	500	V	Information
Insulation	15/07/2015	4.1	MOhm	Pass
IEC Lead Polarity	15/07/2015			Pass
Overall: Pass				

Asset ID: 142050	Description: IEC LEAD	Make:
User: ADAM	Test Instrument: Seaward PrimeTest 350 29A-0467	Comments:

Test Type	Date	Result	Unit	Status
Visual	15/07/2015			Pass
IEC Lead Continuity	15/07/2015	0.104	ohm	Pass
Insulation Voltage	15/07/2015	500	V	Information
Insulation	15/07/2015	4.1	MOhm	Pass
IEC Lead Polarity	15/07/2015			Pass
Overall: Pass				

Asset ID: 142051	Description: SPEAKER	Make: MACKIE
User: ADAM	Test Instrument: Seaward PrimeTest 350 29A-0467	Comments:

Test Type	Date	Result	Unit	Status
Visual	15/07/2015			Pass
Earth Continuity	15/07/2015	0.084	ohm	Pass
Insulation Voltage	15/07/2015	500	V	Information
Insulation	15/07/2015	4.1	MOhm	Pass
Overall: Pass				

Asset ID: 142052	Description: SPEAKER	Make: MACKIE
User: ADAM	Test Instrument: Seaward PrimeTest 350 29A-0467	Comments:

Test Type	Date	Result	Unit	Status
Visual	15/07/2015			Pass
Earth Continuity	15/07/2015	0.134	ohm	Pass
Insulation Voltage	15/07/2015	500	V	Information
Insulation	15/07/2015	6.8	MOhm	Pass
Overall: Pass				

Asset ID: 142053	Description: IEC LEAD	Make:
User: ADAM	Test Instrument: Seaward PrimeTest 350 29A-0467	Comments:

Test Type	Date	Result	Unit	Status
Visual	15/07/2015			Pass
IEC Lead Continuity	15/07/2015	0.096	ohm	Pass
Insulation Voltage	15/07/2015	500	V	Information
Insulation	15/07/2015	4.1	MOhm	Pass
IEC Lead Polarity	15/07/2015			Pass
Overall: Pass				

Asset ID: 142054	Description: AMP	Make: GIULI
User: ADAM	Test Instrument: Seaward PrimeTest 350 29A-0467	Comments:

Test Type	Date	Result	Unit	Status
Visual	15/07/2015			Pass
Earth Continuity	15/07/2015	0.148	ohm	Pass
Insulation Voltage	15/07/2015	500	V	Information
Insulation	15/07/2015	5.5	MOhm	Pass
Overall: Pass				

User: ADAM	Test Instrument: Seaward PrimeTest 350 29A-0467	Comments:
------------	---	-----------

Total Tests: 6

Signed By: 

