


Portable Appliance Testing Report



Presented to

Steve Connolly

363 Wisden Road
Stevenage Herts
SG1 5JN

Tested by

Lowe PAT Testing




Portable Appliance Testing Commencement Date
18/04/2015

PAT Test Summary

Steve Connolly

■ Appliances Passed ■ Appliances Failed






iCertifi PAT Edition

Appliances tested for electrical safety in accordance with the IET code of practice for in service and inspection and testing of electrical equipment



Portable Appliance Test (PAT) Completion Certificate



DETAILS OF THE CLIENT		ADDRESS OF TESTING	
Client and address	Steve Connolly 363 Wisden Road Stevenage Herts	363 Wisden Road Stevenage Herts	
	Postcode: SG1 5JN		Postcode: SG1 5JN
*ANY LIMITATIONS AGREED ON TESTING			
*If any, reasons and with whom agreed		The Premises Are:	<input type="checkbox"/> Domestic <input type="checkbox"/> Commerical <input type="checkbox"/> Industrial
DECLARATION		ENGINEER, NAME & SIGNATURE	
<p>This is to certify the electrical appliances details in this certificate and record sheets have been tested for electrical safety in accordance with the IET code of practice for in service and inspection and testing of electrical equipment. It does not guarantee the correct operation of the appliance for any length of time. Users of the appliance should be aware of any fault or defect that may occur with future use. Any doubt regarding the safety or correct operation of the appliance, the device should be removed from service for further inspection by a competent person.</p>		Signature	 Name: CRAIG LOWE Date: 18/04/2015 
TESTING CARRIED OUT BY		PAT TESTER SERIAL NUMBER	
Trading Title	Lowe PAT Testing		
	Flat 5 13 Haringey Park London		
	Email info@lowepattesting.com		
	Web www.lowepattesting.com		
Telephone No	07966176051		
	Postcode N8 9HY		
Registration No: (if applicable)			
Branch No: (if applicable)			
NOTES			
Tester - uni t ut528 Serial - 814001011			



ANY FAILED APPLIANCES SHOULD BE REMOVED FROM SERVICE UNTIL THE DEFECT HAS BEEN RECTIFIED

APPLIANCE SUMMARY FOR Steve Connolly 363 Wisden Road Stevenage Herts SG1 5JN

Total Appliances

32

Appliances Passed

32

Appliances Failed

0

PORTABLE APPLIANCE REGISTER

Appliance number	Appliance	Class	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection (months)	Combined Inspection & Test (months)	Result
					Earth continuity test (Ω)	Insulation Resistance M(Ω)	Load test (kVA)	Earth Leakage Test (mA)					
860	Mac Charger	2			N/A	>19.99	N/A	0.10	✓		3	12	Pass
861	Mac Charger	2			N/A	19.99	N/A	0.10	✓		3	12	Pass
862	TC Electronics Power Lead	2			N/A	19.99	N/A	0.10	✓		3	12	Pass
863	TC Electronics Power Lead	2			N/A	19.99	N/A	0.10	✓		3	12	Pass
864	Ext Lead				0.040	19.99	N/A	N/A	✓		3	12	Pass
865	Ext Lead				0.06	19.99	N/A	N/A	✓		3	12	Pass
866	Ext Lead				0.07	19.99	N/A	N/A	✓		3	12	Pass
867	IEC Lead				0.14	19.99	N/A	N/A	✓		3	12	Pass
868	IEC Lead				0.19	19.99	N/A	N/A	✓		3	12	Pass
869	IEC Lead				0.10	19.99	N/A	N/A	✓		3	12	Pass
870	IEC Lead				0.04	19.99	N/A	N/A	✓		3	12	Pass
871	Ext Lead				0.20	19.99	N/A	N/A	✓		3	12	Pass
872	Ext Lead				0.08	19.99	N/A	N/A	✓		3	12	Pass
873	Ext Lead				0.10	19.99	N/A	N/A	✓		3	12	Pass
874	IEC Lead				0.04	19.99	N/A	N/A	✓		3	12	Pass
875	Ext Lead				0.20	19.99	N/A	N/A	✓		3	12	Pass

Appliance number	Appliance	Class	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection (months)	Combined Inspection & Test (months)	Result
					Earth continuity test (Ω)	Insulation Resistance M(Ω)	Load test (kVA)	Earth Leakage Test (mA)					
876	Bose Power Stand (For Speakers)	1			0.06	19.99	N/A	0.69	✓		3	12	Pass
877	Allen And Heath Z10fx	1			0.11	19.99	N/A	0.10	✓		3	12	Pass
878	Boss Power Supply	2			N/A	19.99	N/A	0.10	✓		3	12	Pass
879	Boss Gt- 6 Guitar Pedal	2			N/A	19.99	N/A	0.10	✓		3	12	Pass
880	Kam Led Light Barr	1			0.09	19.99	N/A	0.10	✓		3	12	Pass
881	Kam Led Light Barr	1			0.17	03.50	N/A	0.10	✓		3	12	Pass
882	Power Lead	2			N/A	19.99	N/A	0.10	✓		3	12	Pass
883	Korg Micro Arranger	2			N/A	19.99	N/A	0.10	✓		3	12	Pass
884	Adj Dotz Tpar System	1			0.06	19.99	N/A	0.10	✓		3	12	Pass
885	TC Helicon Pedal	2			N/A	19.99	N/A	0.10	✓		3	12	Pass
886	Tc Helicon Harmony G Xt	2			N/A	19.99	N/A	0.10	✓		3	12	Pass
887	Dotz Tpar System Lights	1			0.10	19.99	N/A	0.10	✓		3	12	Pass
888	Ext Lead				0.11	19.99	N/A	0.10	✓		3	12	Pass
889	Sennheiser Wireless Receiver	2			N/A	19.99	N/A	0.10	✓		3	12	Pass
890	Sennheiser Wireless Receiver	2			N/A	19.99	N/A	0.10	✓		3	12	Pass
891	Sure Inear Monitor	2			N/A	>19.99	N/A	0.10	✓		3	12	Pass



Engineers Signature

PT447987

Certificate reference

PAT Test Completion Certificate

for

Steve Connolly

This is to certify the electrical appliances on the premises for the above named have been tested for electrical safety in accordance with the IET code of practice for in service and inspection and testing of electrical test equipment

18/04/2015

Date

Lowe PAT Testing

Tested by