

| Client: Nick Haswell |                              |                          | Site: KT16 8HP |                           | Location: MOBILE LOCATION |
|----------------------|------------------------------|--------------------------|----------------|---------------------------|---------------------------|
| Asset ID: 011815     | Description: LAMPS           | Tested By STEVE MATTHEWS |                | Test Instrument: 09B-0529 |                           |
| Test Type            | Date Tested                  | Result                   | Unit           | Status                    | Retest Period 12 Months   |
| Visual               | 12/06/2014                   |                          |                | Pass                      |                           |
| Earth Continuity     | 12/06/2014                   | 0.054                    | ohm            | Pass                      |                           |
| Insulation Voltage   | 12/06/2014                   | 500                      | V              | Information               |                           |
| Insulation           | 12/06/2014                   | > 199                    | MOhm           | Pass                      |                           |
| Overall: Pass        |                              |                          |                |                           |                           |
| Asset ID: 011816     | Description: IEC LEAD        | Tested By STEVE MATTHEWS |                | Test Instrument: 09B-0529 |                           |
| Test Type            | Date Tested                  | Result                   | Unit           | Status                    | Retest Period 12 Months   |
| Visual               | 12/06/2014                   |                          |                | Pass                      |                           |
| IEC Lead Continuity  | 12/06/2014                   | 0.098                    | ohm            | Pass                      |                           |
| Insulation Voltage   | 12/06/2014                   | 500                      | V              | Information               |                           |
| Insulation           | 12/06/2014                   | > 199                    | MOhm           | Pass                      |                           |
| IEC Lead Polarity    | 12/06/2014                   |                          |                | Pass                      |                           |
| Overall: Pass        |                              |                          |                |                           |                           |
| Asset ID: 011817     | Description: IEC LEAD        | Tested By STEVE MATTHEWS |                | Test Instrument: 09B-0529 |                           |
| Test Type            | Date Tested                  | Result                   | Unit           | Status                    | Retest Period 12 Months   |
| Visual               | 12/06/2014                   |                          |                | Pass                      |                           |
| IEC Lead Continuity  | 12/06/2014                   | 0.052                    | ohm            | Pass                      |                           |
| Insulation Voltage   | 12/06/2014                   | 500                      | V              | Information               |                           |
| Insulation           | 12/06/2014                   | > 199                    | MOhm           | Pass                      |                           |
| IEC Lead Polarity    | 12/06/2014                   |                          |                | Pass                      |                           |
| Overall: Pass        |                              |                          |                |                           |                           |
| Asset ID: 011818     | Description: IEC LEAD        | Tested By STEVE MATTHEWS |                | Test Instrument: 09B-0529 |                           |
| Test Type            | Date Tested                  | Result                   | Unit           | Status                    | Retest Period 12 Months   |
| Visual               | 12/06/2014                   |                          |                | Pass                      |                           |
| IEC Lead Continuity  | 12/06/2014                   | 0.09                     | ohm            | Pass                      |                           |
| Insulation Voltage   | 12/06/2014                   | 500                      | V              | Information               |                           |
| Insulation           | 12/06/2014                   | > 199                    | MOhm           | Pass                      |                           |
| IEC Lead Polarity    | 12/06/2014                   |                          |                | Pass                      |                           |
| Overall: Pass        |                              |                          |                |                           |                           |
| Asset ID: 011819     | Description: LAMPS           | Tested By STEVE MATTHEWS |                | Test Instrument: 09B-0529 |                           |
| Test Type            | Date Tested                  | Result                   | Unit           | Status                    | Retest Period 12 Months   |
| Visual               | 12/06/2014                   |                          |                | Pass                      |                           |
| Earth Continuity     | 12/06/2014                   | 0.076                    | ohm            | Pass                      |                           |
| Insulation Voltage   | 12/06/2014                   | 500                      | V              | Information               |                           |
| Insulation           | 12/06/2014                   | > 199                    | MOhm           | Pass                      |                           |
| Overall: Pass        |                              |                          |                |                           |                           |
| Asset ID: 011820     | Description: IEC LEAD        | Tested By STEVE MATTHEWS |                | Test Instrument: 09B-0529 |                           |
| Test Type            | Date Tested                  | Result                   | Unit           | Status                    | Retest Period 12 Months   |
| Visual               | 12/06/2014                   |                          |                | Pass                      |                           |
| IEC Lead Continuity  | 12/06/2014                   | 0.05                     | ohm            | Pass                      |                           |
| Insulation Voltage   | 12/06/2014                   | 500                      | V              | Information               |                           |
| Insulation           | 12/06/2014                   | > 199                    | MOhm           | Pass                      |                           |
| IEC Lead Polarity    | 12/06/2014                   |                          |                | Pass                      |                           |
| Overall: Pass        |                              |                          |                |                           |                           |
| Asset ID: 011821     | Description: 4 GANG EXT LEAD | Tested By STEVE MATTHEWS |                | Test Instrument: 09B-0529 |                           |
| Test Type            | Date Tested                  | Result                   | Unit           | Status                    | Retest Period 12 Months   |
| Visual               | 12/06/2014                   |                          |                | Pass                      |                           |
| IEC Lead Continuity  | 12/06/2014                   | 0.202                    | ohm            | Pass                      |                           |
| IEC Lead Continuity  | 12/06/2014                   | 0.202                    | ohm            | Pass                      |                           |
| IEC Lead Continuity  | 12/06/2014                   | 0.2                      | ohm            | Pass                      |                           |
| IEC Lead Continuity  | 12/06/2014                   | 0.2                      | ohm            | Pass                      |                           |
| Insulation Voltage   | 12/06/2014                   | 500                      | V              | Information               |                           |
| Insulation           | 12/06/2014                   | > 199                    | MOhm           | Pass                      |                           |
| IEC Lead Polarity    | 12/06/2014                   |                          |                | Pass                      |                           |
| Overall: Pass        |                              |                          |                |                           |                           |

| <b>Asset ID: 011822</b> | <b>Description: 4 GANG EXT LEAD</b> |        | <b>Tested By STEVE MATTHEWS</b> | <b>Test Instrument: 09B-0529</b> |                         |
|-------------------------|-------------------------------------|--------|---------------------------------|----------------------------------|-------------------------|
| Test Type               | Date Tested                         | Result | Unit                            | Status                           | Retest Period 12 Months |
| Visual                  | 12/06/2014                          |        |                                 | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.2    | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.202  | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.204  | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.206  | ohm                             | Pass                             |                         |
| Insulation Voltage      | 12/06/2014                          | 500    | V                               | Information                      |                         |
| Insulation              | 12/06/2014                          | > 199  | MOhm                            | Pass                             |                         |
| IEC Lead Polarity       | 12/06/2014                          |        |                                 | Pass                             |                         |
|                         |                                     |        |                                 |                                  | Overall: Pass           |

| <b>Asset ID: 011823</b> | <b>Description: 4 GANG EXT LEAD</b> |        | <b>Tested By STEVE MATTHEWS</b> | <b>Test Instrument: 09B-0529</b> |                         |
|-------------------------|-------------------------------------|--------|---------------------------------|----------------------------------|-------------------------|
| Test Type               | Date Tested                         | Result | Unit                            | Status                           | Retest Period 12 Months |
| Visual                  | 12/06/2014                          |        |                                 | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.204  | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.208  | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.204  | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.206  | ohm                             | Pass                             |                         |
| Insulation Voltage      | 12/06/2014                          | 500    | V                               | Information                      |                         |
| Insulation              | 12/06/2014                          | > 199  | MOhm                            | Pass                             |                         |
| IEC Lead Polarity       | 12/06/2014                          |        |                                 | Pass                             |                         |
|                         |                                     |        |                                 |                                  | Overall: Pass           |

| <b>Asset ID: 011824</b> | <b>Description: 2 GANG EXT LEAD</b> |        | <b>Tested By STEVE MATTHEWS</b> | <b>Test Instrument: 09B-0529</b> |                         |
|-------------------------|-------------------------------------|--------|---------------------------------|----------------------------------|-------------------------|
| Test Type               | Date Tested                         | Result | Unit                            | Status                           | Retest Period 12 Months |
| Visual                  | 12/06/2014                          |        |                                 | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.12   | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.104  | ohm                             | Pass                             |                         |
| Insulation Voltage      | 12/06/2014                          | 500    | V                               | Information                      |                         |
| Insulation              | 12/06/2014                          | > 199  | MOhm                            | Pass                             |                         |
| IEC Lead Polarity       | 12/06/2014                          |        |                                 | Pass                             |                         |
|                         |                                     |        |                                 |                                  | Overall: Pass           |

| <b>Asset ID: 011826</b> | <b>Description: IEC LEAD</b> |        | <b>Tested By STEVE MATTHEWS</b> | <b>Test Instrument: 09B-0529</b> |                         |
|-------------------------|------------------------------|--------|---------------------------------|----------------------------------|-------------------------|
| Test Type               | Date Tested                  | Result | Unit                            | Status                           | Retest Period 12 Months |
| Visual                  | 12/06/2014                   |        |                                 | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                   | 0.044  | ohm                             | Pass                             |                         |
| Insulation Voltage      | 12/06/2014                   | 500    | V                               | Information                      |                         |
| Insulation              | 12/06/2014                   | > 199  | MOhm                            | Pass                             |                         |
| IEC Lead Polarity       | 12/06/2014                   |        |                                 | Pass                             |                         |
|                         |                              |        |                                 |                                  | Overall: Pass           |

| <b>Asset ID: 011827</b> | <b>Description: AC ADAPTOR</b> |        | <b>Tested By STEVE MATTHEWS</b> | <b>Test Instrument: 09B-0529</b> |                         |
|-------------------------|--------------------------------|--------|---------------------------------|----------------------------------|-------------------------|
| Test Type               | Date Tested                    | Result | Unit                            | Status                           | Retest Period 12 Months |
| Visual                  | 12/06/2014                     |        |                                 | Pass                             |                         |
| Insulation Voltage      | 12/06/2014                     | 500    | V                               | Information                      |                         |
| Insulation              | 12/06/2014                     | > 199  | MOhm                            | Pass                             |                         |
|                         |                                |        |                                 |                                  | Overall: Pass           |

| <b>Asset ID: 011828</b> | <b>Description: 4 GANG EXT LEAD</b> |        | <b>Tested By STEVE MATTHEWS</b> | <b>Test Instrument: 09B-0529</b> |                         |
|-------------------------|-------------------------------------|--------|---------------------------------|----------------------------------|-------------------------|
| Test Type               | Date Tested                         | Result | Unit                            | Status                           | Retest Period 12 Months |
| Visual                  | 12/06/2014                          |        |                                 | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.372  | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.368  | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.366  | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.368  | ohm                             | Pass                             |                         |
| Insulation Voltage      | 12/06/2014                          | 500    | V                               | Information                      |                         |
| Insulation              | 12/06/2014                          | > 199  | MOhm                            | Pass                             |                         |
| IEC Lead Polarity       | 12/06/2014                          |        |                                 | Pass                             |                         |
|                         |                                     |        |                                 |                                  | Overall: Pass           |

| <b>Asset ID: 011829</b> | <b>Description: 4 GANG EXT LEAD</b> |        | <b>Tested By STEVE MATTHEWS</b> | <b>Test Instrument: 09B-0529</b> |                         |
|-------------------------|-------------------------------------|--------|---------------------------------|----------------------------------|-------------------------|
| Test Type               | Date Tested                         | Result | Unit                            | Status                           | Retest Period 12 Months |
| Visual                  | 12/06/2014                          |        |                                 | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.32   | ohm                             | Pass                             |                         |

|                     |            |       |      |             |
|---------------------|------------|-------|------|-------------|
| IEC Lead Continuity | 12/06/2014 | 0.322 | ohm  | Pass        |
| IEC Lead Continuity | 12/06/2014 | 0.32  | ohm  | Pass        |
| IEC Lead Continuity | 12/06/2014 | 0.324 | ohm  | Pass        |
| Insulation Voltage  | 12/06/2014 | 500   | V    | Information |
| Insulation          | 12/06/2014 | > 199 | MOhm | Pass        |
| IEC Lead Polarity   | 12/06/2014 |       |      | Pass        |

Overall: Pass

|                    |             |                               |      |                          |                           |
|--------------------|-------------|-------------------------------|------|--------------------------|---------------------------|
| Asset ID: 011830   |             | Description: LANEY CX SPEAKER |      | Tested By STEVE MATTHEWS | Test Instrument: 09B-0529 |
| Test Type          | Date Tested | Result                        | Unit | Status                   | Retest Period 12 Months   |
| Visual             | 12/06/2014  |                               |      | Pass                     |                           |
| Earth Continuity   | 12/06/2014  | 0.102                         | ohm  | Pass                     |                           |
| Insulation Voltage | 12/06/2014  | 500                           | V    | Information              |                           |
| Insulation         | 12/06/2014  | > 199                         | MOhm | Pass                     |                           |

Overall: Pass

|                    |                              |        |                          |                           |                         |
|--------------------|------------------------------|--------|--------------------------|---------------------------|-------------------------|
| Asset ID: 011831   | Description: SPEAKER SRM 450 |        | Tested By STEVE MATTHEWS | Test Instrument: 09B-0529 |                         |
| Test Type          | Date Tested                  | Result | Unit                     | Status                    | Retest Period 12 Months |
| Visual             | 12/06/2014                   |        |                          | Pass                      |                         |
| Earth Continuity   | 12/06/2014                   | 0.06   | ohm                      | Pass                      |                         |
| Insulation Voltage | 12/06/2014                   | 500    | V                        | Information               |                         |
| Insulation         | 12/06/2014                   | > 199  | MOhm                     | Pass                      |                         |

Overall: Pass

|                    |                              |        |                          |                           |                         |
|--------------------|------------------------------|--------|--------------------------|---------------------------|-------------------------|
| Asset ID: 011832   | Description: SPEAKER SRM 450 |        | Tested By STEVE MATTHEWS | Test Instrument: 09B-0529 |                         |
| Test Type          | Date Tested                  | Result | Unit                     | Status                    | Retest Period 12 Months |
| Visual             | 12/06/2014                   |        |                          | Pass                      |                         |
| Earth Continuity   | 12/06/2014                   | 0.056  | ohm                      | Pass                      |                         |
| Insulation Voltage | 12/06/2014                   | 500    | V                        | Information               |                         |
| Insulation         | 12/06/2014                   | > 199  | MOhm                     | Pass                      |                         |

Overall: Pass

|                    |                         |        |                          |                           |                         |
|--------------------|-------------------------|--------|--------------------------|---------------------------|-------------------------|
| Asset ID: 011833   | Description: MUSTANG IV |        | Tested By STEVE MATTHEWS | Test Instrument: 09B-0529 |                         |
| Test Type          | Date Tested             | Result | Unit                     | Status                    | Retest Period 12 Months |
| Visual             | 12/06/2014              |        |                          | Pass                      |                         |
| Earth Continuity   | 12/06/2014              | 0.072  | ohm                      | Pass                      |                         |
| Insulation Voltage | 12/06/2014              | 500    | V                        | Information               |                         |
| Insulation         | 12/06/2014              | > 199  | MOhm                     | Pass                      |                         |

Overall: Pass

|                    |                           |        |                          |                           |                         |
|--------------------|---------------------------|--------|--------------------------|---------------------------|-------------------------|
| Asset ID: 011834   | Description: MIXER CFX 12 |        | Tested By STEVE MATTHEWS | Test Instrument: 09B-0529 |                         |
| Test Type          | Date Tested               | Result | Unit                     | Status                    | Retest Period 12 Months |
| Visual             | 12/06/2014                |        |                          | Pass                      |                         |
| Earth Continuity   | 12/06/2014                | 0.07   | ohm                      | Pass                      |                         |
| Insulation Voltage | 12/06/2014                | 500    | V                        | Information               |                         |
| Insulation         | 12/06/2014                | > 199  | MOhm                     | Pass                      |                         |

Overall: Pass

|                    |             |                       |      |                          |                           |
|--------------------|-------------|-----------------------|------|--------------------------|---------------------------|
| Asset ID: 011835   |             | Description: FOOTSTER |      | Tested By STEVE MATTHEWS | Test Instrument: 09B-0529 |
| Test Type          | Date Tested | Result                | Unit | Status                   | Retest Period 12 Months   |
| Visual             | 12/06/2014  |                       |      | Pass                     |                           |
| Earth Continuity   | 12/06/2014  | 0.054                 | ohm  | Pass                     |                           |
| Insulation Voltage | 12/06/2014  | 500                   | V    | Information              |                           |
| Insulation         | 12/06/2014  | > 199                 | MOhm | Pass                     |                           |

Overall: Pass

|                     |             |                             |      |                          |                           |
|---------------------|-------------|-----------------------------|------|--------------------------|---------------------------|
| Asset ID: 011836    |             | Description: 6A 2 GANG LEAD |      | Tested By STEVE MATTHEWS | Test Instrument: 09B-0529 |
| Test Type           | Date Tested | Result                      | Unit | Status                   | Retest Period 12 Months   |
| Visual              | 12/06/2014  |                             |      | Pass                     |                           |
| IEC Lead Continuity | 12/06/2014  | 0.09                        | ohm  | Pass                     |                           |
| IEC Lead Continuity | 12/06/2014  | 0.06                        | ohm  | Pass                     |                           |
| Insulation Voltage  | 12/06/2014  | 500                         | V    | Information              |                           |
| Insulation          | 12/06/2014  | > 199                       | MOhm | Pass                     |                           |
| IEC Lead Polarity   | 12/06/2014  |                             |      | Pass                     |                           |

Overall: Pass

| <b>Asset ID: 011839</b> | <b>Description: 6A EXT LEAD</b> |        | <b>Tested By STEVE MATTHEWS</b> | <b>Test Instrument: 09B-0529</b> |                         |
|-------------------------|---------------------------------|--------|---------------------------------|----------------------------------|-------------------------|
| Test Type               | Date Tested                     | Result | Unit                            | Status                           | Retest Period 12 Months |
| Visual                  | 12/06/2014                      |        |                                 | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                      | 0.62   | ohm                             | Pass                             |                         |
| Insulation Voltage      | 12/06/2014                      | 500    | V                               | Information                      |                         |
| Insulation              | 12/06/2014                      | > 199  | MOhm                            | Pass                             |                         |
| IEC Lead Polarity       | 12/06/2014                      |        |                                 | Pass                             |                         |

Overall: Pass

| <b>Asset ID: 011840</b> | <b>Description: IEC LEAD</b> |        | <b>Tested By STEVE MATTHEWS</b> | <b>Test Instrument: 09B-0529</b> |                         |
|-------------------------|------------------------------|--------|---------------------------------|----------------------------------|-------------------------|
| Test Type               | Date Tested                  | Result | Unit                            | Status                           | Retest Period 12 Months |
| Visual                  | 12/06/2014                   |        |                                 | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                   | 0.104  | ohm                             | Pass                             |                         |
| Insulation Voltage      | 12/06/2014                   | 500    | V                               | Information                      |                         |
| Insulation              | 12/06/2014                   | > 199  | MOhm                            | Pass                             |                         |
| IEC Lead Polarity       | 12/06/2014                   |        |                                 | Pass                             |                         |

Overall: Pass

| <b>Asset ID: 011841</b> | <b>Description: 4 GANG EXT LEAD</b> |        | <b>Tested By STEVE MATTHEWS</b> | <b>Test Instrument: 09B-0529</b> |                         |
|-------------------------|-------------------------------------|--------|---------------------------------|----------------------------------|-------------------------|
| Test Type               | Date Tested                         | Result | Unit                            | Status                           | Retest Period 12 Months |
| Visual                  | 12/06/2014                          |        |                                 | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.074  | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.074  | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.074  | ohm                             | Pass                             |                         |
| IEC Lead Continuity     | 12/06/2014                          | 0.09   | ohm                             | Pass                             |                         |
| Insulation Voltage      | 12/06/2014                          | 500    | V                               | Information                      |                         |
| Insulation              | 12/06/2014                          | > 199  | MOhm                            | Pass                             |                         |
| IEC Lead Polarity       | 12/06/2014                          |        |                                 | Pass                             |                         |

Overall: Pass

Total Tests: 24