

CLIENT AND LOCATION DETAILS

Rich Cooper
27 Abbey Drive

Rich Cooper
27 Abbey Drive

Dartford
Kent DA2 7WP

Dartford
Kent DA2 7WP

TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD 5I	Status
0001	iec lead	14/01/2015	1	230	Pass	0.24	>99.90							Pass
0002	iec extension lead	14/01/2015	1	230	Pass	0.57	>99.90							Pass
0003	iec lead	14/01/2015	1	230	Pass	0.07	>99.90							Pass
0004	iec lead	14/01/2015	1	230	Pass	0.09	>99.90							Pass
0005	I phone charger	14/01/2015	2	230	Pass		>99.90	0.00	0.00					Pass
0006	iec lead	14/01/2015	1	230	Pass	0.19	>99.90							Pass
0007	iec lead	14/01/2015	1	230	Pass	0.15	>99.90							Pass
0008	6 way extension lead	14/01/2015	1	230	Pass	0.28	>99.90							Pass
0009	iec lead	14/01/2015	1	230	Pass	0.18	>99.90							Pass
0010	Bose Model 2 Tone Match	14/01/2015	1	230	Pass	0.17	>99.90	0.04	0.59					Pass
0011	Sure Microphone adapter	14/01/2015	2	230	Pass		>99.90	0.00	0.00					Pass
0012	Mackie 1402-vizpro	14/01/2015	1	230	Pass	0.13	>99.90	0.00	0.00					Pass
0013	Fan	14/01/2015	1	230	Pass	0.19	>99.90	0.00	0.00					Pass
0014	Mackie DLM12	14/01/2015	2	230	Pass		>99.90	0.00	0.00					Pass
0015	Mackie DLM12	14/01/2015	2	230	Pass		>99.90	0.00	0.00					Pass
0016	Mackie Dlm12s	14/01/2015	1	230	Pass	0.41	>99.90	0.05	0.79					Pass
0017	iec lead	14/01/2015	1	230	Pass	0.18	>99.90							Pass
0018	Kam Led par bar	14/01/2015	1	230	Pass	0.31	>99.90	0.02	0.21					Pass
0019	iec lead	14/01/2015	1	230	Pass	0.19	>99.90							Pass
0020	Kam led paarbar	14/01/2015	1	230	Pass	0.24	>99.90	0.01	0.00					Pass

CONTRACTOR DETAILS

D.J. Sounds P.A.T. Testing.
73 Highfield Road
Dartford
Kent
DA1 2JU

01322 401499

Tester Name Davis Hare
Qualifications City & Guilds 2377-12
Position P.A.T. Tester

Signature

