

Portable Appliance Testing Log

In-Service Inspection and Testing of Electrical Equipment

PASSED



Emerald
P.A.T
Testing

01924 820148

We provide PAT testing to Small business, Bands, DJ's, Landlords etc. and can often be available at short notice, evenings and weekends. No job too small.


ELECTRICAL
SAFETY TEST

Test Equipment Used	Name and Address of Customer
Model - Primetest 250	Gimme Abba
Serial No - 29C-0998	48 Grove Avenue
Certificate No - 19232	Hemsworth
Date Tested - 08.10.2012	WF9 4JB
Certificate Number - 02-10-13-01	

Results of Tests Carried Out										
ID No	Appliance Description	Appliance Location	Class I or 2	Visual Inspection	Earth Ohms	Insulation Mohms	Leakage mA	Comments Repairs	Next Inspection	PASS FAIL
1	amp	workshop	1	PASS	0.07	>19.99	0.10		Oct 2015	PASS
2	amp lead	workshop	1	PASS	0.10	>19.99	good		Oct 2015	PASS
3	extension lead	workshop	1	PASS	0.20	>19.99	good		Oct 2015	PASS
4	extension lead	workshop	1	PASS	0.05	>19.99	good		Oct 2015	PASS
5	extension lead	workshop	1	PASS	0.19	>19.99	good		Oct 2015	PASS
6	extension lead	workshop	1	PASS	0.05	>19.99	good		Oct 2015	PASS
7	extension lead	workshop	1	PASS	0.05	>19.99	good		Oct 2015	PASS
8	extension lead	workshop	1	PASS	0.05	>19.99	good		Oct 2015	PASS
9	fan	workshop	1	PASS	0.05	>19.99	0.10		Oct 2015	PASS
10	fan	workshop	1	PASS	0.11	>19.99	0.10		Oct 2015	PASS
11	fan	workshop	1	PASS	0.07	>19.99	0.10		Oct 2015	PASS
12	iec lead	workshop	1	PASS	0.09	>19.99	good		Oct 2015	PASS
13	iec lead	workshop	1	PASS	0.05	>19.99	good	5 amp fuse fitted	Oct 2015	PASS
14	iec lead	workshop	1	PASS	0.14	>19.99	good		Oct 2015	PASS
15	iec lead	workshop	1	PASS	0.07	>19.99	good		Oct 2015	PASS
16	iec lead	workshop	1	PASS	0.07	>19.99	good		Oct 2015	PASS
17	iec lead	workshop	1	PASS	0.04	>19.99	good		Oct 2015	PASS
18	iec lead	workshop	1	PASS	0.04	>19.99	good		Oct 2015	PASS
19	iec lead	workshop	1	PASS	0.06	>19.99	good		Oct 2015	PASS
20	iec lead	workshop	1	PASS	0.07	>19.99	good		Oct 2015	PASS
21	iec lead	workshop	1	PASS	0.06	>19.99	good		Oct 2015	PASS
22	iec lead	workshop	1	PASS	0.08	>19.99	good		Oct 2015	PASS
23	amp	workshop	1	PASS	0.10	>19.99	0.10		Oct 2015	PASS
24	amp	workshop	1	PASS	0.10	>19.99	0.10		Oct 2015	PASS
25	amp	workshop	1	PASS	0.10	>19.99	0.10		Oct 2015	PASS
26	transformer	workshop	2	PASS	n/a	>19.99	0.10		Oct 2015	PASS
27	head phone amp	workshop	2	PASS	n/a	>19.99	0.10		Oct 2015	PASS
28	iec lead	workshop	1	PASS	0.05	>19.99	good		Oct 2015	PASS
29	beringer	workshop	2	PASS	n/a	>19.99	0.10		Oct 2015	PASS
30	md player	workshop	2	PASS	n/a	>19.99	0.10		Oct 2015	PASS
31	extension lead	workshop	1	PASS	0.04	>19.99	good		Oct 2015	PASS
32	iec lead	workshop	1	PASS	0.09	>19.99	good		Oct 2015	PASS
33	mixer	workshop	1	PASS	0.13	>19.99	0.10		Oct 2015	PASS
34	extension lead	workshop	1	PASS	0.12	>19.99	good		Oct 2015	PASS
35	transformer	workshop	2	PASS	n/a	>19.99	0.10		Oct 2015	PASS
36	iec lead	workshop	1	PASS	0.05	>19.99	good		Oct 2015	PASS
37	power connector	workshop	1	PASS	0.10	>19.99	good		Oct 2015	PASS
38	amp	workshop	1	PASS	0.11	>19.99	0.10		Oct 2015	PASS
39	power connector	workshop	1	PASS	0.11	>19.99	0.10		Oct 2015	PASS
40	reciever system	workshop	1	PASS	0.11	>19.99	0.10		Oct 2015	PASS
41	iec lead	workshop	1	PASS	0.05	>19.99	good		Oct 2015	PASS
42	mixer	workshop	1	PASS	0.08	>19.99	0.22		Oct 2015	PASS
43	extension lead	workshop	1	PASS	0.05	>19.99	good		Oct 2015	PASS
44	extension lead	workshop	1	FAIL						FAIL
45	transformer	workshop	1	PASS	0.10	>19.99	0.10		Oct 2015	PASS
46	keyboard	workshop	2	PASS	n/a	>19.99	0.24		Oct 2015	PASS
47	led light	workshop	1	PASS	0.06	>19.99	0.29		Oct 2015	PASS
48	led light	workshop	1	PASS	0.01	>19.99	0.29		Oct 2015	PASS
49	led light	workshop	1	PASS	0.05	>19.99	0.27		Oct 2015	PASS
50	led light	workshop	1	PASS	0.08	>19.99	0.27		Oct 2015	PASS

Test Engineer Sign - <i>S W Smith</i>	Test Engineer Name - Stuart Smith	2nd Oct 2013
---------------------------------------	--	--------------

Portable Appliance Testing Log

<p style="font-size: small;">In-Service Inspection and Testing of Electrical Equipment</p> <div style="display: flex; justify-content: space-between; align-items: center;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg); font-weight: bold; border: 1px solid black; padding: 2px;">PASSED</div> <div style="text-align: center;">  <p style="font-weight: bold; font-size: 2em;">01924 820148</p> <p style="font-size: x-small;">We provide PAT testing to Small business, Bands, DJ's, Landlords etc. and can often be available at short notice, evenings and weekends. No job too small.</p> </div> <div style="writing-mode: vertical-rl; transform: rotate(180deg); font-weight: bold; border: 1px solid black; padding: 2px;">ELECTRICAL SAFETY TEST</div> </div>	Test Equipment Used	Name and Address of Customer
	Model - Primetest 250	Gimme Abba
	Serial No - 29C-0998	48 Grove Avenue
	Certificate No - 19232	Hemsworth
	Date Tested - 08.10.2012	WF9 4JB
	Certificate Number - 02-10-13-01	

Results of Tests Carried Out										
ID No	Appliance Description	Appliance Location	Class 1 or 2	Visual Inspection	Earth Ohms	Insulation Mohms	Leakage mA	Comments Repairs	Next Inspection	PASS / FAIL
										PASS / FAIL
51	led light	workshop	1	PASS	0.07	>19.99	0.28		Oct 2015	PASS
52	led light	workshop	1	PASS	0.07	>19.99	0.29		Oct 2015	PASS
53	led light	workshop	1	PASS	0.04	>19.99	0.29		Oct 2015	PASS
54	led light	workshop	1	PASS	0.06	>19.99	0.28		Oct 2015	PASS
55	transformer	workshop	2	PASS	n/a	>19.99	0.10		Oct 2015	PASS
56	power connector	workshop	1	PASS	0.18	>19.99	good		Oct 2015	PASS
57	daiseya MH	workshop	1	PASS	0.02	>19.99	0.10		Oct 2015	PASS
58	daiseya MH	workshop	1	PASS	0.10	>19.99	0.10		Oct 2015	PASS
59	amp	workshop	1	PASS	0.10	>19.99	0.10		Oct 2015	PASS
60	amp	workshop	1	PASS	0.10	>19.99	0.10		Oct 2015	PASS
61	amp	workshop	1	PASS	0.04	>19.99	0.10		Oct 2015	PASS
62	amp	workshop	1	PASS	0.04	>19.99	0.10		Oct 2015	PASS
63	amp	workshop	1	PASS	0.03	>19.99	0.10		Oct 2015	PASS
64	daiseya MH	workshop	1	PASS	0.10	>19.99	0.10		Oct 2015	PASS
65	daiseya MH	workshop	1	PASS	0.10	>19.99	0.10		Oct 2015	PASS
66	extension lead	workshop	1	PASS	0.05	>19.99	good	new plug	Oct 2015	PASS
67	extension lead	workshop	1	PASS	0.02	>19.99	good	rewired	Oct 2015	PASS
68	extension lead	workshop	1	PASS	0.20	>19.99	good	rewired	Oct 2015	PASS

Portable Appliance Testing Log

Failed and Repair Log

In-Service Inspection and Testing of Electrical Equipment



01924 820148

We provide PAT testing to Small business, Bands, DJ's, Landlords etc. and can often be available at short notice, evenings and weekends. No job too small.

Test Equipment Used

Model - Primetest 250
Serial No - 29C-0998
Certificate No - 19232
Date Tested - 08.10.2012

Name and Address of Customer

Gimme Abba
48 Grove Avenue
Hemsworth
WF9 4JB

Certificate Number - 02-10-13-01

Failed Log

Log No	Appliance Description	Appliance Location	Class 1 or 2	Visual Inspection	Earth Ohms	Insulation Mohms	Leakage mA	Comments
44	extension lead	workshop	1	PASS				Earth Leakage Fail

Repaired Log

Log No	Appliance Description	Appliance Location	Class 1 or 2	Visual Inspection	Earth Ohms	Insulation Mohms	Leakage mA	Comments

Test Engineer Sign - <i>S W Smith</i>	Test Engineer Name - Stuart Smith	2nd Oct 2013
---------------------------------------	--	--------------

Portable Appliance Test Certificate

Health and Safety at Work Act (HSWA) Act 1974
Electricity at Work Regulations (EAWR) 1989
Management of Health and Safety at Work Regulations (MHSWR) 1999 amended 2003
Provision and Use of Work Equipment Regulations (PUWER) 1998 amended 2002

This is to certify that an Visual Inspection and Test of
Electrical equipment owned or managed by

Gimme Abba
48 Grove Avenue
Hemsworth
WF9 4JB

Was Carried Out By :-

Stuart Smith of Emerald PAT Testing
on
2nd October 2013

The inspection and tests were carried out in accordance with the above legislation,
and in accordance with the guidance laid down by the Institution of Electrical Engineers
in their Code of Practice for In-Service Inspection and Testing of Electrical Equipment.
The schedule which is provided with this Certificate details the appliances tested
and the results that were obtained.

Results found

Number of Appliances Tested :-	68
Number of Appliances Passed :-	67
Details of Appliances Failed :-	See attached Log for Details
Certificate Reference :-	02-10-13-01
Suggested Re-Test Date :-	2nd October 2015

Test Equipment Used :-

Seaward Primetest 250 s/n 29C-0988
Certificate of Conformity No 19232
Calibration Date 08 October 2012

Signed by Engineer

S W Smith

Stuart Smith
Emerald PAT Testing

